



QWZU.EX27094 Centrifugal Fire Pumps, End Suction

[Page Bottom](#)

Centrifugal Fire Pumps, End Suction

[See General Information for Centrifugal Fire Pumps, End Suction](#)**FULLBLAZE MIDDLE EAST**

EX27094

Expansionist Area- Zarqa Free Zone

PO Box 19083

Amman, 11196 JORDAN

Rated Capacity GPM	Size In.	Model Dsg	Rated Net Pressure Range psi	Approx Speed RPM	Max Working Pressure psi
50	2.5x1.5	FBP-E-65/40	95-136	2900	200
100	2.5x1.5	FBP-E-65/40	91-131	2900	200
150	2.5x1.5	FBP-E-65/40	82-123	2900	200
150	3x2	FBE-E-80/50	110-140	2900	225
200	3x2	FBE-E-80/50	106-137	2900	225
250	3x2	FBE-E-80/50	98-133	2900	225
400	5x3	FBP-E-125/80	85-137	2900	225
450	5x3	FBP-E-125/80	83-137	2900	225
450	5x4	FBP-E-125/100	133-211	2900	290
500	5x3	FBP-E-125/80	82-136	2900	225
500	5x4	FBP-E-125/100	133-210	2900	290
750	5x4	FBP-E-125/100	126-204	2900	290

[Last Updated](#) on 2017-01-04[Questions?](#)[Print this page](#)[Terms of Use](#)[Page Top](#)

© 2016 UL LLC

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2016 UL LLC".



Certificate of Compliance

This certificate is issued for the following:

Centrifugal Fire Pumps - Axial Split-Case Type

FBP-S-80/270

FBP-S-100/310

FBP-S-125/290

(See Listing Attached)

Prepared for:

Fullblaze Middle East
Zarqua Free Zone New Expansionist Area
Amman 11192
Jordan

FM Approvals Class: 1311, dated January 2018

Approval Identification: 0003062763

Approval Granted: January 14, 2019

To verify the product continues to be Approved please refer to www.approvalguide.com.

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in dark ink, appearing to read "D.B. Fuller", is written over a horizontal line.

David B. Fuller
VP, Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062 USA



Member of the FM Global Group



QXJY.EX27302 Centrifugal Fire Pumps, Split Case

[Page Bottom](#)

Centrifugal Fire Pumps, Split Case

[See General Information for Centrifugal Fire Pumps, Split Case](#)**FULLBLAZE MIDDLE EAST**

EX27302

Expansionist Area- Zarqa Free Zone

PO Box 19083

Amman, 11196 JORDAN

Fire pumps, single stage

Rated Capacity (gpm)	Size (in.)	Model Dsg	Rated Net Pressure Range (psi)	Approx Speed (rpm)	Max Working Pressure (psi)
500	5x3	FBP-S-80/270	90-159	2980	253
750	6x4	FBP-S-100/310	120-239	2980	326
1000	6x4	FBP-S-100/310	110-235	2980	326
1250	8x5	FBP-S-125/290	124-200	2980	290
1500	8x5	FBP-S-125/290	117-192	2980	290

Last Updated on 2017-01-04

[Questions?](#)[Print this page](#)[Terms of Use](#)[Page Top](#)

© 2016 UL LLC

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2016 UL LLC".



Certificate of Compliance

Product	Listing Country	Rated Capacity, (gal/min)	Rated Capacity, (dm ³ /min)	Rated Net Head at Rated Capacity, psi	Rated Net Head at Rated Capacity, kPa	Rated Speed, r/min	Suction Inlet, dia., in.	Discharge Outlet, dia., in.	Stage(s)	Certification Type
FBP-S-80/270	Jordan	500	1893	106-170	731- 1172	2980	5	3	1	FM Approved
FBP-S-100/310	Jordan	750	2839	143-245	986- 1689	2980	6	4	1	FM Approved
FBP-S-100/310	Jordan	1000	3785	121-243	834-1675	2980	6	4	1	FM Approved
FBP-S-125/290	Jordan	1250	4732	133-206	917- 1420	2980	8	5	1	FM Approved
FBP-S-125/290	Jordan	1500	5680	136-201	938- 1386	2980	8	5	1	FM Approved



Member of the FM Global Group